

STATE OF INDIANA
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
PUBLIC NOTICE NO. 20230309 – INP000617 – D
DATE OF NOTICE: MARCH 9, 2023
DATE RESPONSE DUE: APRIL 10, 2023

The Office of Water Quality proposes the following NPDES DRAFT PERMIT:

PRETREATMENT – MODIFICATION

GRIOTS GARAGE, Permit No. INP000617, HENDRICKS COUNTY, 2185 Airwest Blvd, Plainfield, IN. This pretreatment facility is a car cleaner/polish manufacturer which discharges 0.00325 million gallons daily of sanitary and process wastewater to the Plainfield South WWTP. The modification reflects the pH change in local SUO. Permit Manager: Matt Warrener, 317/233-0798, mwarrene@idem.IN.gov. Posted online at <https://www.in.gov/idem/public-notices/>.

PROCEDURES TO FILE A RESPONSE

Draft can be viewed or copied (10¢ per page) at IDEM/OWQ NPDES PS, 100 North Senate Avenue, (Rm 1203) Indianapolis, IN, 46204 (east end elevators) from 9 – 4, Mon - Fri, (except state holidays). A copy of the Draft Permit is on file at the local County Health Department. Please tell others you think would be interested in this matter. For your rights & responsibilities see: Public Notices: <https://www.in.gov/idem/public-notices/>; Citizen Guide: <https://www.in.gov/idem/resources/citizens-guide-to-idem/>. Please tell others whom you think would be interested in this matter.

Response Comments: The proposed decision to issue a permit is tentative. Interested persons are invited to submit written comments on the Draft permit. All comments must be postmarked no later than the Response Date noted to be considered in the decision to issue a Final permit. Deliver or mail all requests or comments to the attention of the Permit Writer at the above address, (mail code 65-42 PS).

To Request a Public Hearing:

Any person may request a Public Hearing. A written request must be submitted to the above address on or before the Response Date noted. The written request shall include: the name and address of the person making the request, the interest of the person making the request, persons represented by the person making the request, the reason for the request and the issues proposed for consideration at the Hearing. IDEM will determine whether to hold a Public Hearing based on the comments and the rationale for the request. Public Notice of such a Hearing will be published in at least one newspaper in the geographical area of the discharge and sent to anyone submitting written comments and/or making such request and whose name is on the mailing list at least 30 days prior to the Hearing.



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

March 9, 2023

VIA ELECTRONIC MAIL

Mr. Arnie Rojas, Director of Fulfillment Operations
Griot's Garage, Inc.
2185 Airwest Boulevard
Plainfield, IN 46168

Dear Mr. Rojas:

Re: IWP Permit No. INP000617
Draft Permit Modification
Griot's Garage, Inc.
Plainfield, Indiana - Hendricks County

Your request for a permit modification has been reviewed and processed in accordance with rules adopted under 327 IAC 5. The enclosed Pages 1 through 2 of 23 are intended to replace the corresponding pages of your existing IWP Permit No. INP000617. An accompanying Briefing Memo itemizes and explains the rationale for the revisions.

Pursuant to IC 13-15-5-1, IDEM will publish the draft permit document online at <https://www.in.gov/ide/public-notices/>. Additional information on public participation can be found in the "Citizens' Guide to IDEM", available at <https://www.in.gov/ide/resources/citizens-guide-to-idem/>. A 30-day comment period is available to solicit input from interested parties, including the public.

Please review this draft permit modification and associated documents carefully to become familiar with the proposed terms and conditions. Comments concerning the draft permit modification should be submitted in accordance with the procedure outlined in the enclosed public notice form. We suggest that you meet with us to discuss major concerns or objections you may have with the draft permit modification.



Questions concerning this draft permit modification may be addressed to Matt Warrener of my staff, at 317-233-0798 or by email at mwarrene@idem.in.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Richard Hamblin", with a long horizontal flourish extending to the right.

Richard Hamblin, Chief
Industrial NPDES Permits Section
Office of Water Quality

Enclosures

cc: Hendricks County Health Department
Mr. Jason Castetter, Plainfield South POTW
Leigh Voss, IDEM
Mr. Jason Palin, IDEM

STATE OF INDIANA

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
AMENDED AUTHORIZATION TO DISCHARGE UNDER THE
INDUSTRIAL WASTEWATER PRETREATMENT PROGRAM

INDUSTRIAL WASTEWATER PRETREATMENT (IWP) PERMIT

In accordance with 327 IAC 5-21 and IDEM's permitting authority under IC 13-15, **Griot's Garage, Inc.** (hereinafter referred to as the permittee) is authorized to discharge, from the facility located at 2185 Airwest Boulevard, Plainfield, Indiana into the **Plainfield South Publicly Owned Treatment Works (POTW)**, in accordance with the effluent limitations, monitoring requirements, and other conditions set forth in Parts I and II hereof.

The permit, as issued on October 26, 2022, is hereby amended, as contained herein. The amended provisions shall become effective _____. All terms and conditions of the permit not modified at this time remain in effect. Further, any existing condition or term affected by the amendments will remain in effect until the amended provisions become effective. This permit and the authorization to discharge, as amended, shall expire at midnight November 30, 2027.

NOTE: In order to receive authorization to discharge beyond the date of expiration, the permittee must submit a renewal IWP permit application to the Industrial NPDES Permit Section in the Office of Water Quality, no later than one hundred and eighty (180) days prior to the date this permit expires. Failure to do so will result in expiration of the authorization to discharge.

Signed on _____ for the Indiana Department of
Environmental Management.

Jerry Dittmer, Chief
Permits Branch
Office of Water Quality

PART I

(A) EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

(1) During the period beginning on the effective date of this permit, the permittee is authorized to discharge from Outfall 001[1][2]. Outfall 001 is located at an outside manhole on the north side of the building. Such discharge shall be limited and monitored by the permittee as specified below:

Table 1

<u>Parameter</u>	<u>Discharge Limitations</u>		<u>Unit</u>	<u>Monitoring Requirements</u>	
	<u>Daily Maximum</u>	<u>Monthly Average</u>		<u>Measurement Frequency</u> [4]	<u>Sample Type</u> [3]
Flow [5]	Report [7]	Report [7]	MGD	1 X Monthly	24-Hr. Total
BOD	Report [7]	Report [7]	mg/l	1 X Monthly	24-Hr. Comp.
COD	Report [7]	Report [7]	mg/l	1 X Monthly	24-Hr. Comp.
TSS	Report [7]	Report [7]	mg/l	1 X Monthly	24-Hr. Comp.
Oil & Grease (O&G)	Report [7]	Report [7]	mg/l	1 X Monthly	Grab
Closed Cup Flashpoint	Report [9]	Report [9]	°F	1 X Monthly	Grab

Table 2

<u>Parameter</u>	<u>Quality or Concentration</u>			<u>Monitoring Requirements</u>	
	<u>Daily Minimum</u>	<u>Daily Maximum</u>	<u>Units</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
pH [6]	5.0 [8]	10.0 [8]	s.u.	1 X Weekly	Grab

- [1] Outfall 001 shall be designated as the combined wastestreams at the point of discharge to the POTW.
- [2] The discharge shall not exceed the local limits in the Sewer Use Ordinance upon entering the POTW.
- [3] A "24-hour composite sample" means a sample consisting of at least three (3) individual flow-proportional samples of wastewater, consisting of aliquots withdrawn throughout the 24-hour discharge period. The aliquots may be: (i) uniform aliquots withdrawn at uniform flow intervals; (ii) flow-proportional aliquots withdrawn at uniform time intervals; or (iii) for batch discharge, uniform aliquots withdrawn from uniform batch volumes. A flow-proportioned composite sample may be obtained by:



Industrial Wastewater Pretreatment (IWP)

Briefing Memo for
Griot's Garage, Inc.

Draft modification March 2023

Final modification TBD

Indiana Department of Environmental Management

100 North Senate Avenue
Indianapolis, Indiana 46204

(317) 232-8603

Toll Free (800) 451-6027

www.idem.IN.gov

Permittee:	Griot's Garage, Inc. 2185 Airwest Boulevard Plainfield, Indiana 46168
Existing Permit Information:	Permit Number: INP000617 Expiration Date: November 30, 2027
Facility Contact:	Mr. Arnie Rojas, Director of Fulfillment Operations 317-839-2135 arojas@griotsgarage.com
Facility Location:	2185 Airwest Boulevard Plainfield, Indiana 46168 Hendricks County
Receiving POTW:	Plainfield South Wastewater Treatment Plant 775 South and County Road 725 East Plainfield, Indiana NPDES Permit IN0062456
Proposed Permit Action:	Modify
Source Category	Industrial Pretreatment
Permit Writer:	Matt Warrenner, Permit Writer 317-233-0798 mwarrene@idem.in.gov

Table of Contents

1.0 Introduction.....3

2.0 PERMIT MODIFICATION.....3

2.1 Modification Request.....3

2.2 IDEM’s Proposed Modification.....3

3.0 Permit Processing/Public Comment.....3

1.0 INTRODUCTION

The Indiana Department of Environmental Management (IDEM) received a request from Griot's Garage, Inc. on February 22, 2023 to modify Industrial Wastewater Pretreatment (IWP) Permit INP000617. The current five year permit was issued with an effective date of December 1, 2022 in accordance with 327 IAC 5-2-6(a).

In accordance with Title 40 of the Code of Federal Regulations (CFR) Sections 124.7 and 124.56, as well as Indiana Administrative Code (IAC) 327 Article 5, development of a Statement of Basis, or Briefing Memo, is required for NPDES permits. This document fulfills the requirements established in those regulations.

This Briefing Memo identifies the basis for this modification to the permit and the modified pages of the permit issued on October 26, 2022.

2.0 PERMIT MODIFICATION

2.1 Modification Request

The permittee submitted a request for modification on February 22, 2023 to update the pH limits to reflect the Town of Plainfield Sewer Use Ordinance (SUO), which was updated in June 2017. The pH limits included in the updated SUO are 5.0 as a Daily Minimum and 10.0 as a Daily Maximum.

2.2 IDEM's Proposed Modification

The permit will be modified to reflect the pH limits contained in the Town of Plainfield SUO which was updated in June 2017. PH limits of 5.0 as a Daily Minimum and 10.0 as a Daily Maximum have been added to the permit modification.

3.0 Permit Processing/Public Comment

Pursuant to IC 13-15-5-1, IDEM will publish the draft permit document online at <https://www.in.gov/idem/public-notices/>. Additional information on public participation can be found in the "Citizens' Guide to IDEM", available at <https://www.in.gov/idem/resources/citizens-guide-to-idem/>. A 30-day comment period is available to solicit input from interested parties, including the public.